



SEWER TAP CHECKLIST

Public Works Department/Sewer
Division

255 Mooney Dr.

Bourbonnais, IL 60914

815-937-0817 • Fax 815-937-3574

publicworks@villageofbourbonnais.com

EFFECTIVE IMMEDIATELY

DO NOT backfill until we have personally marked "OK" on the ground with a green flag!!!

- Use 4" Schedule 40, or 6" SDR 35 Pipe
- Minimum of 1/8" Slope
- Cleanout must be a minimum of 18" from foundation but not exceed 5'
- Gasketed push pipe or glue fittings permitted (no flexible couplings)
- Pipe must be bedded in stone, not in dirt
- 22°, 45° and soft sweep (minimum sweep) 90° elbows are acceptable on bends.
- For inspections, crown of pipe from foundation to stub must be visible – **NO EXCEPTIONS!**
- After inspection passes, 6" of stone must be laid over pipe.
- Excavated drives and sidewalks shall be filled to grade with gravel after approval.
- 48-HOUR ADVANCE NOTICE REQUIRED** on lines to be inspected.
- Under **NO EXCEPTIONS** should sump pump lines be tapped into sanitary lines.
- Sewer and water placed side-by-side must be 10' apart. If sewer and water are crossed, they must be 18" apart height-wise. The water line has to be above the sewer line.